



DOUBLE SERVICE MANIFOLD

NOT TO SCALE

NOTES:

1. USE CORPORATION STOP CONNECTION. SEE DETAIL 701.
2. FOR 5/8" x 3/4" METER SETTERS, MANIFOLD SHALL BE 6" LONG.
FOR 1" METER SETTERS, MANIFOLD SHALL BE 12" LONG.
3. FOR 5/8" x 3/4" METER SETTERS, MANIFOLD SIZE SHALL BE 3/4" FROM BUSHING AT TEE.
FOR 1" METER SETTERS, MANIFOLD SIZE SHALL BE 1" FROM BUSHING AT TEE.
4. FOR 5/8" x 3/4" METER SETTERS, USE 1-17"x30" METER BOX AS SHOWN.
FOR 1" METER SETTERS, USE INDIVIDUAL METER BOXES SIMILAR TO THE SINGLE SERVICE DETAIL 703.
5. THE METER BOX SHALL BE CENTERED OVER THE METER SETTER ASSEMBLY AS SHOWN.

APPROVED: LYNN ARAKAKI
REV. DATE: SEPT. 24, 1999

WATER/WASTEWATER DIVISION



STANDARD DETAILS

DOUBLE SERVICE MANIFOLD

FILE SD703A.DWG DRAWING NO. **703A**